

(By Hand / Speed Post / Regd Post)

GOVERNMENT OF INDIA
CENTRAL PUBLIC WORKS DEPARTMENT

No.27(9)2016/AE(E)/NITPESD/ Wg/2.2.4

Date: 28/11/2016

To,
The Principal,
Kendriya Vidyalaya,
Nalgonda, Telangana.

Sub : Providing building safety certificate & fire safety certificate - Reg
Ref : KV principal Lr No : F.No-21015/KVNGL/2016-17 dt: 25/11/2016

Sir,


Kendriya vidyalaya school building, Nalgonda was constructed by CPWD and handed over during the year 2014. It seems that, at that time occupancy NOC for fire safety was not obtained by school authorities from DFO, Nalgonda. Now in response to the request made by the Principal, kendriya vidyalaya, nalgonda vide the above cited letter under reference, the fire fighting installations viz., downcomer system with first aid hose reels, at kendriya vidyalaya, Nalgonda have been got checked through an agency specialised in firefighting installations, to the effect of its operational functionality for assessing fire safety of the school building. As reported, it appears that the operational functionality of the equipment for the building fire safety is satisfactory.

In this connection the following suggestions are made for future compliance.

1. Conducting periodical fire mock drills, by operating the firefighting equipment in presence of office staff.
2. Maintaining a log book/ register showing the details of periodical mock fire drills conducted.
3. Immediate & periodical refilling of the fire extinguishers with appropriate extinguishing mediums before lapse of due date for refilling.
4. Upkeeping of fire controls panels, pump sets and other related equipment.


Thanking You

Yours faithfully


Assistant Engineer (Elect),
NITPESD, CPWD,
NIT campus, Warangal.

- Copy to 1) The Executive Engineer (E), HCED-I, Hyderabad for information please.
2) The Junior Engineer (E), NITPESD, Warangal for information.

- Sd -
Assistant Engineer (Elect),


Principal
केन्द्रीय विद्यालय
Kendriya Vidyalaya
Nalgonda


Sudarshan